



## Smart Solutions Bristol Ltd

117 Wedmore Vale, Bristol, BS3 5EW  
smartsolutionsltd.com • Company 16203244

# Certificate of Ventilation System Cleaning

Kitchen extract system cleaned to TR19 Grease specification

**FULL CLEAN**

**SITE CLEANED**  
**Main Kitchen**

The Larkmoor Hotel, 40 Aldwick Parade, Bristol, BS8 1TY

| MEAN POST-CLEAN DEPOSIT (WFTTM) | RESULT      | NEXT CLEAN / INSPECTION DUE |
|---------------------------------|-------------|-----------------------------|
| 19.0 $\mu\text{m}$              | <b>PASS</b> | 29 September 2026           |

**DATE CLEAN UNDERTAKEN**  
29 June 2026

**PVR REFERENCE**  
1004

**SYSTEM**  
Kitchen Extraction

**SMART CERTIFICATE REFERENCE**  
EU64-S5ZA

### CLEANING FREQUENCY - ENGINEER'S DETERMINATION

Quarterly - Table 4 used due to it being the initial clean (High usage, 12 - 16 hours per day)

The cleaning frequency above is the determination of a competent person using TR19 Grease Tables 4/5 and reflects the historic usage of this system. Seasonal variation and changes in cooking type or volume may require reassessment. This certificate must be read in conjunction with Post Clean Verification Report 1004, which forms part of this pack. To confirm the authenticity of this document, quote the certificate reference above to Smart Solutions Bristol Ltd.



**Main Kitchen**

29 June 2026, EU64-S5ZA

**DEMONSTRATION - NOT A COMPLIANCE RECORD**

Your trade body's  
badge here

**Smart Solutions Bristol Ltd**